

## **SECTION 8**

### **8.12 INSTALLATION OF VALVES:**

Valves shall be handled in such a manner as to prevent any injury or damage. Valves shall be set and joined to pipe in the manner previously specified for cleaning, laying and joining mechanical and push on joints. Valves shall be set in such a manner that the valve stems are plumb. Valves shall be wrapped with polyethylene encasement material to protect the mechanical joint as specified in 6.41, A.

Valves shall be located at the point on the main, which would be intersected by the street property line extended and as outlined in 5.10. Any deviations from this shall be at the discretion of Denver Water.

If so ordered by Denver Water, valves shall be operated prior to installation to ensure good operating condition.